



NOTES:

1. NEW BASIS NO. FC132418C02 OR EQUAL
2. ALL CONDUITS MUST BE ON ONE SIDE OF BOX.
3. MUST HAVE DIMENSION OF 15" WIDE X 25" LONG AND 18" DEEP.

<i>Detail No.</i>	 City of Needles STANDARD DETAIL	SECONDARY HAND HOLE BOX SPECIFICATION	<i>Revised</i>	<i>Detail No.</i>
EHH-1			06/27/07	EHH-1