



NOTES:

MINIMUM WINDOW AREA (EXTERIOR GLAZED OPENING) MUST BE AT LEAST 1/10 OF THE FLOOR AREA OF ROOM(S) SERVED, WITH A MINIMUM OF 10 SQ FT; ONE-HALF OF REQUIRED AREA MUST BE OPENABLE.

MAXIMUM AREA OF EXTERIOR GLAZED OPENING(S) MAY NOT EXCEED 16% OF THE FLOOR AREA(S) OF THE ADDITIONS(S), PLUS ANY EXISTING EXTERIOR GLAZED OPENING(S) THAT ARE BEING REMOVED. UNLESS SUBSTANTIATING CALCULATIONS ARE SUBMITTED.

SAMPLE FLOOR PLAN

SCALE: N.T.S. (NOT TO SCALE)